



CERTIFICATE OF CONSTANCY OF PERFORMANCE

1720-CPR-0105

In compliance with Statutory Instruments 2019 No.465 of the United Kingdom Houses of Parliament 5th March 2019 (The Construction Products (Amendment etc.) (EU Exit) Regulations 2019), this certificate applies to the construction product:

***Ryobi D-2050 Door Closer (Regular & Transom applications)
single or double action closer with adjustable closing force***

an overhead closer with adjustable closing force for use on fire resisting and smoke control doors
with the following classification:

4	8	5	1	1	3
		3			

produced by or for

Ryobi Limited

5-2-8 Toshima, Kita-ku, Tokyo 114-8518, JAPAN

and produced in the manufacturing plant(s)

Factory Code: J-A

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

BS EN 1154:1997 + A1:2002

Under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 1st January 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are not modified significantly unless suspended or withdrawn by the approved product certification body.



Princes Risborough, UK

Director of Certification

IFC Certification Ltd
UK Approved Body No. 1720

20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK
Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: info@ifccertification.com
Registered No: 4777898 England
©IFC Certification Ltd 2021